

# Annexure C

## PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. LAB/ MDB /MAY /61

Dated: 12/05/2026


It is certified that an inspection team headed by Raman Kumar Jha Lab. Asst. (Name of Officers with designation) from PHED Madhubani

inspected the DELHI PUBLIC SCHOOL, BASUARA SADAR, DIST- MADHUBANI (BIHAR) PIN 847212 (Name & Address of the school) on 11-05-2026 (date of inspection) and on the basis of Water Test

Report (Attached) bearing no LAB/MAY/61 dated 12/05/2026 of Madhubani (PHED Lab)


certified that the DELHI PUBLI SCHOOL ( Name of school) has safe drinking water facilities for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

This certificate is valid till 31.03.2027

Signature with Seal:  12/05/26

Name : ASRAF NAJMI

Designation : CHEMIST

Name & Address of the Office / Department: 

TO,  
THE PRINCIPAL  
DELHI PUBLIC SCHOOL, DIST-  
MADHUBANI(BIHAR) PIN847212  
(Name & Address of the Institution)

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies

**DISTRICT LEVEL WATER TESTING LABORATORY  
P.H.DIVISION, MADHUBANI**

Sampling Date:- 11/05/2026

Testing Date:- 12/05/2026

Months:- MAY 2026.


Sample Collected & Submitted by RAMAN JHA.

Sl No.	Block	Panchayat	Village	Source of Water	Name of Location/Nearest Person	PH.	Tub.	T.H	T.A	Ca	Mg	Cl	Fe	F	SO4	NO3	TDS	Remarks
1	RAHIKA	BASUARA	BASUARA	BORING	DELHI PUBLIC SCHOOL, BASUARA MADHUBANI.	7.4	2.5	147	214	30	10	24	0.36	0.12	00	0.5	254	
Min-Max-Permissible Limit						6.5 - 8.5	1.0-05	200 - 600	200 - 600	75 - 200	30 - 100	250 - 1000	1.0	1 - 1.5	200 - 400	45	500 - 2000	

\*NT - Not Tested


\*BDL- Below Detection Limit

NOTE:- THIS REPORT IS VALID FOR 4 MONTHS FROM THE DATE OF TESTING.

  
12/05/2026

Lab Assistant

District Laboratory, Madhubani

  
12/5/26

Chemist

District Laboratory, Madhubani